



CHEMICAL WATER ANALYSIS TEST REPORT

Source of Sample:- Submersible

Agency/Deptt.:- ST Gopal Public School, Shyamon Baroli Aheer Agra-(UP)

Date And Time of Collection:- 02.05.2026 (9:15 AM)

Date And Time of Receipt:- 02.05.2026 (01:30 PM)

S.No.	Parameters	IS : 10500(2012)	Result	Unit
1	Turbidity	1.0-5.0	0.2	NTU/l
2	Colour	5.0-15.0	NIL	P.Scale
3	pH	6.5-8.5	7.29	-
4	Total Dissolved Solids (TDS)	500.2-2000.0	790	Mg/L
5	Total Hardness as CaCo ₃	200-600	130	Mg/L
6	Calcium Hardness	-	120	Mg/L
7	Magnesium Hardness	-	110	Mg/L
8	Total Alkalinity (M) as CaCo ₃	200.0-600.0	228	Mg/L
9	Chlorides	250.1000	248	Mg/L
10	Sulphate	200-400	174	Mg/L
11	Nitrates	45-100	NIL	Mg/L
12	Flourides	1.0-1.5	1.2	Mg/L
13	Calcium as Ca ⁺⁺	75.0-200.2	48	Mg/L
14	Magnicium as Mg ⁺⁺	30.0-100	26.84	Mg/L
15	Iron as fe	0.30-1.0	0.30	Mg/L
16	Maganese	0.1-0.3	0.20	Mg/L

THE SAMPLE IS COLLECTED AND
DEPOSITED BY THE PARTY ITSELF

Bacteriological Test Report

			Result	
1	Coliform	NIL	NIL	CFU/100 MI
2	E. Coil	NIL	NIL	CFU/100 MI

Remark:- The result conforms to standard IS : 10500 (2012) hence potable.

14 Chief Chemist
30/05/2026
Jalkal Vibhag, Nagar Nigam, Agra

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. CHC/B, AHIR/HYG./SANI./2026-77

Dated: 23-05-2026

It is certified that an inspection team headed by Dr. AMIT PANDEY, MEDICAL SUPERINTENDENT

(Name of Officers with designation) from C.H.C. BAROLI AHEER.....PHED

inspected the ST. GOPAL PUBLIC SCHOOL, SHYAMON, BAROLI AHEER
AGRA

(Name & Address of the school) on 23-05-2026 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. dated 14-05-2026

of JALKAL VIBHAG, NAGARNIGAM (PHED Lab) certified that

the ST. GOPAL PUBLIC SCHOOL..... (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till JUNE 2027

Signature with Seal:

Name

Designation

Name & Address of the Office / Department : C.H.C.,

BAROLI AHEER, AGRA.

To

ST. GOPAL PUBLIC SCHOOL
SHYAMON, BAROLI AHEER, AGRA

(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies